



ENTECH
 ENGINEERING, INC.
 505 Elkton Drive
 Colorado Springs, CO 80907
 (719) 531-5599 • (719) 531-5238 (fax)

Client:	FLRD #6
Project:	Forest Lakes Residential Development, Filing 6
Entech Job #	201326

CONCRETE TEST

J. Barnhart			Test #:			30		
Date:	# of Specimens	Specified Strength (psi)	Time of Test	Hours Field Cured	Lab Receive Date:			
6/17/2022	4	4500	1:35 PM	24	6/18/2022			

Specimen Type	Test Type	Type of Cure
Cylinders 4x8	Field	Lab

Contractor:	Supplier:	Mix Design Number
Trax Construction	Transit Mix	T34592110

Truck Number	Ticket Number	Batch Time:
29	86494450	12:12 PM

Location:
 Sidewalk; 20' North off of 4585 Mesa Top Drive.

Slump (in.):	Air (%):	Unit Weight (PCF):	Concrete Temp (°F)	Air Temp (°F)
3.0	6.0	140.2	91	84

7-Day Strength	28-Day Strength	-Day Strength	56-Day Strength	-Day Strength
5210				
Average:	Average:	Average:	Average:	Average:
5210				
Break Date:	Break Date:	Break Date:	Break Date:	Break Date:
6/24/2022	7/15/2022			

Remarks:
 7 Day Results.

Specifications:	Break Sequence:
4000 PSI, 5-8% Air	1@7, 3@28

Summary Comments:
 Trax Construction, Transit Mix

Reviewed By: