

**OFFICE OF THE STATE ENGINEER  
COLORADO DIVISION OF WATER RESOURCES**

818 Centennial Bldg., 1313 Sherman St., Denver, Colorado 80203  
(303) 866-3581

WELL PERMIT NUMBER		056914		F	
DIV. 8	WD 10	DES. BASIN 4	MD 12		

APPLICANT

RONALD G OHOLENDT  
223 OTIS STREET  
COLORADO SPRINGS, CO 80916-

(719) 637-1436

**PERMIT TO CONSTRUCT A WELL**

APPROVED WELL LOCATION

EL PASO COUNTY  
SE 1/4 SW 1/4 Section 12  
Township 12 S Range 65 W Sixth P.M.

DISTANCES FROM SECTION LINES

1276 Ft. from South Section Line  
2396 Ft. from West Section Line

UTM COORDINATES

Northing: Easting:

CONDITIONS OF APPROVAL

- 1) This well shall be used in such a way as to cause no material injury to existing water rights. The issuance of this permit does not assure the applicant that no injury will occur to another vested water right or preclude another owner of a vested water right from seeking relief in a civil court action.
- 2) The construction of this well shall be in compliance with the Water Well Construction Rules 2 CCR 402-2, unless approval of a variance has been granted by the State Board of Examiners of Water Well Construction and Pump Installation Contractors in accordance with Rule 18.
- 3) Approved pursuant to Section 37-90-107, C.R.S., and the Findings and Order of the Colorado Ground Water Commission dated January 30, 1998, for permit number 49451-F. If the well is not operated in accordance with the permit conditions of approval and the above Commission order, it will be subject to administration, including orders to cease diverting water.
- 4) The maximum pumping rate of this well shall not exceed 15 GPM.
- 5) The annual withdrawal of ground water from this well shall not exceed .56 acre-foot.
- 6) The use of ground water from this well is limited to residential use to serve one single family dwelling, irrigation not to exceed 4000 square feet of lawn and garden area, and the watering of domestic animals.
- 7) This well must be constructed to withdraw water from only the Dawson aquifer. The top of the Dawson aquifer is located approximately 100 feet below the ground surface and the bottom of the aquifer is located approximately 740 feet below the ground surface. Plain casing must be installed, grouted and sealed to prevent the diversion of water from other aquifers and the movement of water between aquifers.
- 8) The owner shall mark the well in a conspicuous place with well permit number and name of aquifer as appropriate, and shall take necessary means and precautions to preserve these markings.
- 9) This well shall be constructed within 200 feet of the location specified on this permit within Lot 21 of the Sylvan Meadows, Filing 2, Subdivision and, except for other residential wells located in said Sylvan Meadows Subdivision, shall not be located within 600 feet of another large-capacity well completed in the Dawson aquifer.
- 10) A totalizing flow meter must be installed on the well and maintained in good working order. Permanent records of all diversions must be maintained by the well owner (collected at least annually) and submitted to the Upper Black Squirrel Creek Ground Water Management District and the Ground Water Commission upon request.
- 11) The return flow from the use of this well must be through an individual waste water disposal system of the non-evaporative type where the water is returned to the same stream system in which the well is located.

NOTE: The ability of this well to withdraw its authorized amount of water from this non-renewable aquifer may be less than the 100 years upon which the amount of water in the aquifer is allocated, due to anticipated water level declines.

NOTE: This well is located within a Ground Water Management District where local District Rules may apply to the withdrawal of designated ground water currently authorized under this permit.

APPROVED  
IDC

State Engineer

By

Receipt No. 0484973

DATE ISSUED DEC 13 2001

EXPIRATION DATE DEC 13 2002