

Yes there is. The water quality SNOUT needs a DMA.

NO WATER QUALITY & DETENTION FACILITY IS PROPOSED WITH THIS PROJECT. THE EXISTING SUB-REGIONAL POND SR4 WAS DESIGNED TO PROVIDE WATER QUALITY AND DETENTION FOR THIS SITE. THEREFORE, NO DETENTION MAINTENANCE AGREEMENT & EASEMENT IS REQUIRED.