



Prevent • Promote • Protect

Environmental Health Division
1675 W. Garden of the Gods Road
Suite 2044
Colorado Springs, CO 80907
(719) 578-3199 *phone*
(719) 578-3188 *fax*
www.elpasocountyhealth.org

Midway Ranches Fil. No. 7, Vacation of Interior Lot Lines, VR-20-2

Please accept the following comments from El Paso County Public Health regarding the 238.3-acre lot area proposed to have interior lot lines vacated from 19 existing lots.

- **Wastewater services are not required for this proposal except for the use of portable toilets twice per year when panels are washed, and the future installation of an OWTS for the Operation and Management Facility. This OWTS is required to be designed by a Colorado Registered Professional Engineer.**
- **Wigwam Mutual Water District will provide water taps to be used for cleaning of the solar panels two times per year once the facility is in operation, and for the water tank at the Operation and Management Facility.**
- **Earthmoving activities greater than 25 acres require a Construction Activity Permit from the Colorado Department of Public Health and Environment, Air Pollution Control Division. Please contact the Air Pollution Control Division at for permit information <https://www.colorado.gov/pacific/cdphe/air-permits-contacts>**

Mike McCarthy
El Paso County Public Health
719.575.8602
mikemccarthy@elpasoco.com
21May2020