

# ENG-SF22025-R1-CDs.pdf Markup Summary

8/29/2022 2:47:18 PM (1)



**Subject:** Cloud+  
**Page Index:** 1  
**Date:** 8/29/2022 2:47:18 PM  
**Author:** eschoenheit  
**Color:** ■  
**Layer:**  
**Space:**

PCD File # 22-025


8/29/2022 2:50:12 PM (1)



**Subject:** Cloud+  
**Page Index:** 1  
**Date:** 8/29/2022 2:50:12 PM  
**Author:** eschoenheit  
**Color:** ■  
**Layer:**  
**Space:**

These GEC plan standard notes are not needed on the Construction Drawings. The are listed on the GEC plan. Can remove


8/29/2022 3:14:41 PM (1)



**Subject:** Cloud+  
**Page Index:** 2  
**Date:** 8/29/2022 3:14:41 PM  
**Author:** eschoenheit  
**Color:** ■  
**Layer:**  
**Space:**

Adjust to meet K value of 37


8/29/2022 3:24:57 PM (1)



**Subject:** Cloud+  
**Page Index:** 2  
**Date:** 8/29/2022 3:24:57 PM  
**Author:** eschoenheit  
**Color:** ■  
**Layer:**  
**Space:**

Add posted speed 25mph


8/30/2022 11:02:40 AM (1)



**Subject:** Cloud+  
**Page Index:** 2  
**Date:** 8/30/2022 11:02:40 AM  
**Author:** eschoenheit  
**Color:** ■  
**Layer:**  
**Space:**

Add Plat note that Lot #5 will require an Engineer approved site plan to include drainage  
Extend drainage easement area to account for 30" RCP pipe into Lot #4 and ponding area  
Show riprap detail

8/30/2022 2:47:24 PM (1)




**Subject:** Cloud+  
**Page Index:** 2  
**Date:** 8/30/2022 2:47:24 PM  
**Author:** eschoenheit  
**Color:** ■  
**Layer:**  
**Space:**

Recommend adding inlet protection or create a intercept collection basin

---

8/31/2022 12:16:59 PM (1)

---




**Subject:** Callout  
**Page Index:** 2  
**Date:** 8/31/2022 12:16:59 PM  
**Author:** dsdrice  
**Color:** ■  
**Layer:**  
**Space:**

Provide mailbox pullout details. Mailbox should not be in a snow storage area

---

8/31/2022 12:18:53 PM (1)

---



**Subject:** Callout  
**Page Index:** 2  
**Date:** 8/31/2022 12:18:53 PM  
**Author:** dsdrice  
**Color:** ■  
**Layer:**  
**Space:**

Provide specific ditch cross-sections

---

8/31/2022 12:21:34 PM (1)

---




**Subject:** Callout  
**Page Index:** 2  
**Date:** 8/31/2022 12:21:34 PM  
**Author:** dsdrice  
**Color:** ■  
**Layer:**  
**Space:**

Show headwater ponding area and easement

---

8/31/2022 12:22:37 PM (1)

---




**Subject:** Callout  
**Page Index:** 2  
**Date:** 8/31/2022 12:22:37 PM  
**Author:** dsdrice  
**Color:** ■  
**Layer:**  
**Space:**

Provide culvert profiles

---

8/31/2022 12:22:57 PM (1)

---




**Subject:** Callout  
**Page Index:** 2  
**Date:** 8/31/2022 12:22:57 PM  
**Author:** dsdrice  
**Color:** ■  
**Layer:**  
**Space:**

show drainage easement

---

8/31/2022 12:23:27 PM (1)


---



**Subject:** Callout  
**Page Index:** 2  
**Date:** 8/31/2022 12:23:27 PM  
**Author:** dsdrice  
**Color:** ■  
**Layer:**  
**Space:**

Adjust overlapping text


8/31/2022 12:23:56 PM (1)



**Subject:** Callout  
**Page Index:** 2  
**Date:** 8/31/2022 12:23:56 PM  
**Author:** dsdrice  
**Color:** ■  
**Layer:**  
**Space:**

Adjust cul-de-sac grade to meet criteria


8/31/2022 12:25:14 PM (1)



**Subject:** Callout  
**Page Index:** 2  
**Date:** 8/31/2022 12:25:14 PM  
**Author:** dsdrice  
**Color:** ■  
**Layer:**  
**Space:**

Label existing road grade. Why are there 2 lines?

8/31/2022 12:26:46 PM (1)



**Subject:** Callout  
**Page Index:** 2  
**Date:** 8/31/2022 12:26:46 PM  
**Author:** dsdrice  
**Color:** ■  
**Layer:**  
**Space:**

Roadside ditches will need permanent erosion protection. Address in FDR and show on plan and ditch cross-sections.

8/31/2022 12:35:33 PM (1)

Show and label water lines. Plans with district approval blocks will be required

**Subject:** Text Box  
**Page Index:** 2  
**Date:** 8/31/2022 12:35:33 PM  
**Author:** dsdrice  
**Color:** ■  
**Layer:**  
**Space:**

Show and label water lines. Plans with district approval blocks will be required

8/31/2022 12:37:30 PM (1)



**Subject:** Callout  
**Page Index:** 1  
**Date:** 8/31/2022 12:37:30 PM  
**Author:** dsdrice  
**Color:** ■  
**Layer:**  
**Space:**

Provide plans for north cul-de-sac also

8/31/2022 12:37:51 PM (1)

Cursory comments

**Subject:** Text Box  
**Page Index:** 1  
**Date:** 8/31/2022 12:37:51 PM  
**Author:** dsdrice  
**Color:** ■  
**Layer:**  
**Space:**

Cursory comments