



Prevent • Promote • Protect

Environmental Health Division
1675 W. Garden of the Gods Road
Suite 2044
Colorado Springs, CO 80907
(719) 578-3199 *phone*
(719) 578-3188 *fax*
www.elpasocountyhealth.org

Vollmer-Vollmer Tap 115Kv Transmission and Substation, AASI-19-006

Please accept the following comments from El Paso County Public Health for the project referenced above:

- The project has been approved by all the required review agencies with the submittal. The necessary permits required have been favorably reviewed and obtained or are in process.
- Noise and magnetic field studies were reviewed and models of the proposed substation indicate compliance with Federal Regulations.
- Earthmoving activity in excess of one acre, but less than twenty-five acres, requires a local Construction Activity Permit from El Paso County Public Health. Go to <https://www.elpasocountyhealth.org/service/air-quality/construction-activity-application> for more information.
- The water quality basin must have mosquito control responsibilities included as a part of the construction design and maintenance plan to help control mosquito breeding habitat and minimize the potential for West Nile Virus.

Mike McCarthy
El Paso County Public Health
Environmental Health Division
719.575.8602
mikemccarthy@elpasoco.com
16Jan2020