

OLIVER E. WATTS PE-LS

Please note that parking areas with more than 5 parking spaces are required to provide lighting. Please provide us with a photometric plan showing lighting in the critical areas of the site (the area leading from parking area into the building).

Light

DATE: August 20, 2020

JOB NO.: 20-5449

CLIENT: Fuel Missions

There will be NO
exterior lighting
associated with this
project

Lighting Plan_V1.pdf Markup Summary

1 (1)



There will be NO

Subject: Callout
Page Label: 1
Author: Sophie Kiepe
Date: 1/21/2021 3:59:55 PM
Status:
Color: ■
Layer:
Space:

Please note that parking areas with more than 5 parkign spaces are required to provide lighting. Please provide us with a photometric plan showing lighting in the critical areas of the site (the area leading from parking area into the building).