



Prevent • Promote • Protect

Environmental Health Division
1675 W. Garden of the Gods Road
Suite 2044
Colorado Springs, CO 80907
(719) 578-3199 *phone*
(719) 578-3188 *fax*
www.elpasocountyhealth.org

Security Water and Sanitation District, Drinking Water Mitigation System,
AASI-19-002

Please accept the following comments from El Paso County Public Health for the project referenced above:

- The construction of the Drinking Water Mitigation System must meet the design criteria of the Colorado Department of Public Health and Environment, Water Quality Control Division.
- Earthmoving activity in excess of one acre, but less than twenty-five acres, requires a local Construction Activity Permit from El Paso County Public Health. Go to <https://www.elpasocountyhealth.org/service/air-quality/construction-activity-application> for more information.
- Erosion and stormwater quality to be controlled per El Paso County requirements to minimize sediment runoff from the site.

Mike McCarthy, R.E.H.S.
El Paso County Public Health
Environmental Health Division
719.575.8602
mikemccarthy@elpasoco.com
03Apr2019