



Prevent • Promote • Protect

Environmental Health Division  
1675 W. Garden of the Gods Road  
Suite 2044  
Colorado Springs, CO 80907  
(719) 578-3199 *phone*  
(719) 578-3188 *fax*  
[www.elpasocountyhealth.org](http://www.elpasocountyhealth.org)

### Haddock Metal Roof, CC-20-1

Please accept the following comments from El Paso County Public Health for the commercial community request referenced above:

- **El Paso County Public Health requires the onsite wastewater treatment system (OWTS) to be designed by a Colorado Registered Professional Engineer because the operation is commercial. The original OWTS was Professional Engineer designed, installed and approved in 1985 for the vet clinic that burned down during the 2013 Black Forest Wildfire. Use of this system will require an engineer to evaluate the condition and size of the OWTS for the proposed change in use or be abandoned and a new designed OWTS be installed.**
- **The water system will not require Colorado Department of Public Health and Environment (CDPHE) oversight due to the limited population served.**
- **The water quality basin must have mosquito control responsibilities included as a part of the construction design and maintenance plan to help control mosquito breeding habitat and minimize the potential for West Nile Virus.**

**Mike McCarthy**  
El Paso County Public Health  
Environmental Health Division  
719.575.8602  
[mikemccarthy@elpasoco.com](mailto:mikemccarthy@elpasoco.com)  
06Oct2020