



Prevent • Promote • Protect

Environmental Health Division
1675 W. Garden of the Gods Road
Suite 2044
Colorado Springs, CO 80907
(719) 578-3199 *phone*
(719) 578-3188 *fax*
www.elpasocountyhealth.org

Bourne Accessory Living Quarters, AL-20-21

Please accept the following comments from El Paso County Public Health for the special use project referenced above:

- Water service for the both the existing dwelling and the proposed second dwelling is by an existing individual private well.
- The onsite wastewater treatment system (OWTS) for the existing dwelling was installed and approved for a 3-bedroom house in 1995. A permit to install a new OWTS for the proposed second dwelling was issued on 25Nov2020. The location of the existing soil treatment area (STA) must be located and protected from compaction during the installation of the second dwelling and the associated OWTS. The new OWTS components must meet the minimum horizontal installation setbacks from the well and all property lines.
- No public health issues noted with the approval of this request.

Mike McCarthy
El Paso County Public Health
Environmental Health Division
719.575.8602
mikemccarthy@elpasoco.com
05Dec2020