

Prevent • Promote • Protect

## Circle K at New Meridian and Hwy 24, CS-21-3

Please accept the following comments from El Paso County Public Health for the current zoning of C-2 and RR5 to CS commercial service:

- No El Paso County Public Health issues noted with the zone change request.
- There have been several repairs to the onsite wastewater treatment system (OWTS) at the gas station on the project site. High ground water in the area has contributed to the failures. Extension of central wastewater service to the site would provide a long-term solution should the OWTS fail again in the future.

Mike McCarthy El Paso County Public Health 719.575.8602 <u>mikemccarthy@elpasoco.com</u> 01January2022