



Prevent • Promote • Protect

Environmental Health Division
1675 W. Garden of the Gods Road
Suite 2044
Colorado Springs, CO 80907
(719) 578-3199 *phone*
(719) 578-3188 *fax*
www.elpasocountyhealth.org

10850 E. Woodmen Road, D49 Addition, PPR-25-3

Please accept the following comments from El Paso County Public Health (EPCPH) regarding the project referenced above:

- **Water and wastewater services were not identified with the submittal; however, the Site Development Plan did indicate the location of central water and wastewater mainlines in Bent Grass Meadows Drive off the NE end of the property.**
 - **The new structures planned for the site are dry structures and will not be connected to the existing water and sewer. The Assessor's Office did not indicate what district provides water and wastewater service to the property.**
- **Earthmoving activity more than one acre, but less than twenty-five acres, requires a local Construction Activity Permit from El Paso County Public Health. Go to <https://www.elpasocountyhealth.org/service/air-quality/construction-activity-application> for more information.**
- **No approval issues noted by EPCPH.**

Mike McCarthy
El Paso County Public Health
719-332-5771
mikemccarthy@elpasoco.com
14Feb2025