


# ENG-EGP20007-R2-GEC.pdf Markup Summary

1 (2)




**Subject:** Stamp - Stormwater Comment Legend  
**Page Index:** 1  
**Date:** 12/1/2021 9:46:08 AM  
**Author:** GReese  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [1] Layout1



**Subject:** Contractor  
**Page Index:** 1  
**Date:** 12/1/2021 9:47:17 AM  
**Author:** GReese  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [1] Layout1

(Note that comments on Sht 2 are the same comments submitted to EDARP on 11/16/2021 for EGP207)

2 (6)




**Subject:** Callout  
**Page Index:** 2  
**Date:** 11/22/2021 10:58:40 AM  
**Author:** CDurham  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [1] Layout1

Delete labels, as not part of Early Grading



**Subject:** Callout  
**Page Index:** 2  
**Date:** 11/22/2021 11:00:03 AM  
**Author:** CDurham  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [1] Layout1

Hard to tell where these easements are.




**Subject:** Contractor  
**Page Index:** 2  
**Date:** 12/1/2021 9:45:53 AM  
**Author:** GReese  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [1] Layout1

Add some text like: "developer/contractor to decide locations in the field such the concentrated flows will be prevented from exiting the sites, and rather directed towards TSB's."



**Subject:** Contractor  
**Page Index:** 2  
**Date:** 12/1/2021 9:45:53 AM  
**Author:** GReese  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [1] Layout1


How is flow conveyed from concentrated flows in rough cut streets into TSB? Consider having a berm/swale or some other means to route flows into TSB.



---

**Subject:** Contractor  
**Page Index:** 2  
**Date:** 12/1/2021 9:45:53 AM  
**Author:** GReese  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [1] Layout1

show approximate footprint of this TSB so it is clear which flows are to be captured by it.



---

**Subject:** Callout  
**Page Index:** 2  
**Date:** 12/3/2021 2:16:15 PM  
**Author:** dsdrice  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [1] Layout1

Walls are not approved as part of early grading. separate from the gas main as appropriate.