



Prevent • Promote • Protect

Environmental Health Division
1675 W. Garden of the Gods Road
Suite 2044
Colorado Springs, CO 80907
(719) 578-3199 *phone*
(719) 578-3188 *fax*
www.elpasocountyhealth.org

Lot 2,3 Rolling Thunder, PPR-20-10

Please accept the following comments from El Paso County Public Health regarding the project referenced above:

- Water service is provided by Falcon Highlands Metropolitan District. Wastewater service is provided by Woodmen Hills Metropolitan District.
- Radon resistant construction building techniques/practices are encouraged to be used in this area. The EPA has determined that Colorado, and the El Paso County area have potentially higher radon levels than other areas of the country.
- Earthmoving activity in excess of one acre, but less than twenty-five acres, requires a local Construction Activity Permit from El Paso County Public Health. Go to <https://www.elpasocountyhealth.org/service/air-quality/construction-activity-application> for more information.
- El Paso County Public Health encourages planned walkability of commercial/residential communities. Please consider appropriate connections to any commercial/residential areas to the new school through the use of sidewalks, appropriate lighting and bike trails. Walkability features help reduce obesity and associated heart diseases.

Mike McCarthy
Environmental Health Division
719.575.8602 (O)
mikemccarthy@elpasoco.com
22April2020