



Prevent • Promote • Protect

Environmental Health Division
1675 W. Garden of the Gods Road
Suite 2044
Colorado Springs, CO 80907
(719) 578-3199 *phone*
(719) 578-3188 *fax*
www.elpasocountyhealth.org

Falcon Fire #3, EX-20-2

Please accept the following comments from El Paso County Public Health regarding for Subdivision Exemption, EX-20-2:

- **The 6.85-acre site development is currently provided water and wastewater services by an individual well and onsite wastewater treatment system (OWTS) that serves the 24/7 fire station. The plan is to remodel the station as an administrative building for the District and continue to the 24/7 use as a fire station.**
- **Wastewater and water services by Woodmen Hills Metropolitan District are available to the property and the plan is proceed with connection. The existing OWTS must be abandoned per the current OWTS Regulations.**
- **Earthmoving activity in excess of one acre, but less than twenty-five acres, will require a Construction Activity Permit from El Paso County Public Health. Go to <http://www.elpasocountyhealth.org/service/air-quality> for more information.**

Mike McCarthy
El Paso County Public Health
719.575.8602 (O)
mikemccarthy@elpasoco.com
16June2020