Concrete Test

Entech Engineering
505 Elkton Dr.
Colorado Springs , CO 80907
Phone: 719-531-5599

Client:
Classic Communities
2138 Flying Horse Club Drive
Colorado Springs, CO 80921

Project:
221459
Jackson Creek Parkway & State Highway 105
Jackson Creek Parkway & State Highway 105
Monument, CO

Set #: 34 **Sample #:** 6834 **Placement Date:** 02/06/2026 **Technician:** Jayce Barnhart **Weather Conditions:** Sunny **Air Temp (°F):** 51

Contractor: K&S Enterprises **Supplier:** SRM **Mix Design:** CDOT45878-4 **Specified Strength (psi):** 4500

Placement Location: Curb & Gutter **Location Details:** Curb and Gutter on median of Jackson Creek Pkwy. South of the Intersection of Jackson Creek Pkwy. and Fat Tire Dr. **Lat/Long:** 39.0907314 / -104.856161

PLACEMENT DATA

Set #	Truck # Ticket #	Load Vol (yd³)	Slump (in)	Air Content (%)	Unit Weight (lb/ft³)	Concrete Temp (°F)	Air Temp (°F)
34	2105 14048185	8.00	Slump: 5 Spec: 4 - 6	Result: 6 Spec.: 5 - 8	140.4	72	51

STRENGTH DATA

Set / Test	Age (days)	Test Date	Strength (psi)	Fracture Pattern
34 / 22362	7	02/13/2026	3520	Type 2

Aver**age Strength (psi):** 7 Day - 3520 psi

02/18/2026
Reviewed by: Dylan Gassmann, PE