Concrete Test

Entech Engineering
505 Elkton Dr.
Colorado Springs , CO 80907
Phone: 719-531-5599

Client:
Classic Communities
2138 Flying Horse Club Drive
Colorado Springs, CO 80921

Project:
221459
Jackson Creek Parkway & State Highway 105
Jackson Creek Parkway & State Highway 105
Monument, CO

Set #: 39 **Sample #:** 6992 **Placement Date:** 02/19/2026 **Technician:** Dillon Mercer **Weather Conditions:** Sunny **Air Temp (°F):** 30

Contractor: Enterprise Inc **Supplier:** SRM **Mix Design:** CDOT45878-4 **Specified Strength (psi):** 4500

Placement Location: Other **Location Details:** Median along Jackson Creek Pkwy., immediately South of the intersection of Jackson Creek Pkwy. and Hwy 105 **Lat/Long:** 39.09270676 / -104.8549686

PLACEMENT DATA

Set #	Truck # Ticket #	Load Vol (yd³)	Slump (in)	Air Content (%)	Unit Weight (lb/ft³)	Concrete Temp (°F)	Air Temp (°F)
39	4104 14048584	10.00	Slump: 5 Spec: 3 - 5	Result: 5.5 Spec.: 5 - 8	139.7	63	30

STRENGTH DATA

Set / Test	Age (days)	Test Date	Strength (psi)	Fracture Pattern
39 / 22885	7	02/26/2026	4580	Type 5

Aver**age Strength (psi):** 7 Day - 4580 psi

03/04/2026
Reviewed by: Dylan Gassmann, PE