Concrete Test

Entech Engineering
505 Elkton Dr.
Colorado Springs , CO 80907
Phone: 719-531-5599

Client:
Classic Communities
2138 Flying Horse Club Drive
Colorado Springs, CO 80921

Project:
221459
Jackson Creek Parkway & State Highway 105
Jackson Creek Parkway & State Highway 105
Monument, CO

Set #: 32 **Sample #:** 6753 **Placement Date:** 02/02/2026 **Technician:** Kirby Hooker **Weather Conditions:** Cloudy **Air Temp (°F):** 54

Contractor: K&S Enterprises **Supplier:** SRM **Mix Design:** CDOT45878-4 **Specified Strength (psi):** 4500

Placement Location: Sidewalk **Location Details:** Sidewalk and Pedestrian Ramps on Southeast Corner of Jackson Creek Pkwy. and Highway 105

PLACEMENT DATA

Set #	Truck # Ticket #	Load Vol (yd³)	Slump (in)	Air Content (%)	Unit Weight (lb/ft³)	Concrete Temp (°F)	Air Temp (°F)
32	2216 21190831	4.00	Slump: 3 Spec: 3 - 7	Result: 5 Spec.: 5 - 8	141.6	62	54

STRENGTH DATA

Set / Test	Age (days)	Test Date	Strength (psi)	Fracture Pattern
32 / 22065	7	02/09/2026	4720	Type 3
32 / 22066	28	03/02/2026	5810	Type 3
32 / 22067	28	03/02/2026	5470	Type 2
32 / 22068	28	03/02/2026	5690	Type 3

Aver**age Strength (psi):** 7 Day - 4720 psi, 28 Day - 5660 psi

03/09/2026
Reviewed by: Dylan Gassmann, PE