



**ENTECH**  
ENGINEERING, INC.

505 ELKTON DRIVE  
COLORADO SPRINGS, CO 80907  
PHONE (719) 531-5599  
FAX (719) 531-5238

July 30, 2021

Proterra Properties  
1864 Woodmoor Drive, Suite 100  
Monument, CO 80132

Attn: Joe Desjardin

Re: Density Testing – Storm Sewer  
Winsome, LLC  
Colorado Springs, Colorado  
Report No. 3, Test 5

Dear Mr. Desjardin,

As requested, personnel of Entech Engineering, Inc. have performed density testing at the above referenced site.


Density testing on this site was performed on July 21, 2021. The density testing indicates that the materials have been adequately compacted at the depths and in the locations noted. Results of the density tests are enclosed with this letter.

We trust that this has provided you with the information you require. Should you have any questions or need further information, please do not hesitate to contact us.

Respectfully Submitted,

ENTECH ENGINEERING, INC.

  
Joseph C. Goode,  
President



JCG/kw

Enclosure

Entech Job No. 202064

F:\AA projects\2020\202064-Proterra-Winsome, LLC-110-ConMat\202064\_4cl3.doc

<b>Client:</b> Proterra Properties	<b>Entech Job #:</b> 202064.4	<b>Proctor Value Key:</b> M = modified, ASTM D-1557
<b>Project:</b> Winsome, LLC	<b>Tested By:</b> R. Lewis	S = standard, ASTM D-698
<b>Subject:</b> Storm Sewer	<b>Report Date:</b> 07-30-2021	T = AASHTO, T-180

Test #	Location	Testing Date	Percent Compaction	Percent Required	Percent Moisture	Soil Type	Proctor Type/Value	Pass/Fail
--------	----------	--------------	--------------------	------------------	------------------	-----------	--------------------	-----------

5	(39.0819004, -104.6130255) Trickle Channel Subgrade, at grade.	7/21/21	95	95	6.4	SM	M - 124.9 @ 8.1	<input checked="" type="checkbox"/> = Fail <input type="checkbox"/>
---	--	---------	----	----	-----	----	-----------------	---

**Comments:**

Scope of Observation: PERIODIC; CONTRACTOR'S OR CLIENT'S REPRESENTATIVE ADVISED

All dimensions are approximate. Cl. = Centerline

 <p><b>ENTECH</b> ENGINEERING, INC. 505 Elkton Drive Colorado Springs, CO 80907 (719) 531-5599 • (719) 531-5238 (fax)</p>	<p>FIELD DENSITY RESULTS</p>	<p><i>Joseph C. Goode, Jr., P.E.</i></p>
--	------------------------------	--