

AMENDMENT TO THE MDDP FOR WATERVIEW NORTH

SUBMITTAL #5 – Response to Comment

Our comparison totaling the discharge of Pond JCD-D with the bypass flows from Basins JCD OS-1A and JCD OS-1B is misleading and confusing and we have corrected our error. Our totaling of these numbers was our attempt to provide information to the county about the flow east of the property, but misled the reviewer concerning the comparison of historic onsite flows detained in Pond JCD-D and the detained discharges. We have corrected the tables accordingly.

The minor and major pre-developed peak flow rates combined from basins JCD-EX3.1 & JCD-EX3.2 are 12 cfs and 84 cfs respectively. The comparison for these historic peak flows occurs at the Pond JCD-D outlet structure. The resulting peak discharge from this pond is 10 and 83 for the minor and major events, respectively. These peak flow rates do not exceed the pre-developed peak flow rates.

We apologize for the confusion.