




Water Quality Control Division

Drinking Water Construction Completion as Approved Certification Form

Instructions:

1. Upon completion of construction and **prior** to commencing operations, please complete this form and submit online at wqcdcompliance.com/login (preferred), or by fax/mail (listed below).
2. A revised Monitoring Plan which includes all new facilities must be submitted to the Division within 30 days of construction completion. Please submit Monitoring Plans online at wqcdcompliance.com/login.
3. Any items requested in the design approval letter must also be addressed or submitted to the Division with this form.

A. Project and System Information			
PWS ID	CO0121724		
System Name	Sterling Ranch Metropolitan District No. 1		
Project Title	New Treatment Facility and Well		
County	El Paso		
B. Project Approval Information			
Project Approval Date	March 3, 2020		
Division Reviewer	Anthony Kerr		
C. Project Operational Dates			
Actual Operational Date	March 4, 2020		
Anticipated Operational Date	N/A		
D. Project comments (Include any changes made from the design approval letter)			
<p>The drain line drainage gate is on order and will be installed upon receipt. In the interim, a 12-mesh non-corrodible screen has been securely attached to the end of the drain line.</p> <p>The overflow flapper gate is on order and will be installed upon receipt. In the interim, a 12-mesh non-corrodible screen has been securely attached to the end of the overflow between two (2) flange faces.</p>			
E. Construction As Approved Certification Form			
<p>I certify that to the best of my knowledge, information and belief, based on limited site observation per the contract between <u>MMI Water Engineers, LLC / Bradley A. Simons, P.E.</u> (Professional Engineer* / entity responsible for construction) and the Public Water System (listed above) and information furnished by others that the drinking water project(s) was constructed consistent with the design documents as approved by the Water Quality Control Division.</p>			
Role	Date	Typed Name & Company	Signature
Project Manager	04/01/2020	Bradley A. Simons / MMI Water Engineers, LLC	

*A Professional Engineer registered in the State of Colorado is required to design all treatment systems for a community system.

Submit Online (preferred): wqcdcompliance.com/login - Use "Requests and Other Certifications" Category
 Fax: (303) 758-1398
 WQCD - Drinking Water CAS
 4300 Cherry Creek Drive South; Denver, CO 80246-1530