



Prevent • Promote • Protect

Environmental Health Division
1675 W. Garden of the Gods Road
Suite 2044
Colorado Springs, CO 80907
(719) 578-3199 *phone*
(719) 578-3188 *fax*
www.elpasocountyhealth.org

Falcon Fire #3, PPR-20-24

Please accept the following comments from El Paso County Public Health regarding the project referenced above:

- **The 6.85-acre site development is currently provided water and wastewater services by an individual well and onsite wastewater treatment system (OWTS) that serves the 24/7 fire station. The plan is to remodel the station as an administrative building for the Fire District and continue the 24/7 use as a fire station.**
- **Wastewater and water services by Woodmen Hills Metropolitan District will be connected to the structures. The existing OWTS was abandoned per the current OWTS Regulations.**
- **Earthmoving activity in excess of one acre, but less than twenty-five acres, will require a Construction Activity Permit from El Paso County Public Health. Go to <http://www.elpasocountyhealth.org/service/air-quality> for more information.**

Mike McCarthy
El Paso County Public Health
719.575.8602 (O)
mikemccarthy@elpasoco.com
15August2020