

Stormwater Detention and Infiltration Design Data Sheet

Workbook Protected

Worksheet Protected

Stormwater Facility Name: PRIVATE FULL SPECTRUM DETENTION POND

Facility Location & Jurisdiction: CROSSROADS MIXED USE FILING NO. 1

User Input: Watershed Characteristics

Watershed Slope = 0.006 ft/ft
 Watershed Length = 1725 ft
 Watershed Area = 32.10 acres
 Watershed Imperviousness = 78.7% percent
 Percentage Hydrologic Soil Group A = 100.0% percent
 Percentage Hydrologic Soil Group B = 0.0% percent
 Percentage Hydrologic Soil Groups C/D = 0.0% percent

Location for 1-hr Rainfall Depths (use dropdown):

User Input ▼

WQCV Treatment Method = Extended Detention ▼

User Defined Stage [ft]	User Defined Area [ft^2]	User Defined Stage [ft]	User Defined Discharge [cfs]
0.00	126	0.00	0.00
0.32	241	0.32	0.00
1.32	584	1.32	0.00
2.32	4,627	2.32	0.02
3.32	10,590	3.32	0.03
4.32	20,623	4.32	0.04
5.32	30,665	5.32	0.05
6.32	39,263	6.32	0.06
7.32	43,385	7.32	1.00
8.32	47,718	8.32	7.00
9.32	65,080	9.32	82.70

After completing and printing this worksheet to a pdf, go to:
<https://maperture.digitaldataservices.com/gvh?viewer=cswdif>
 create a new stormwater facility, and
 attach the pdf of this worksheet to that record.

Routed Hydrograph Results

	WQCV	2 Year	5 Year	10 Year	50 Year	100 Year	
Design Storm Return Period =	0.53	1.19	1.50	1.75	2.25	2.52	in
One-Hour Rainfall Depth =	0.857	2.271	2.926	3.563	5.082	5.859	acre-ft
Calculated Runoff Volume =							
OPTIONAL Override Runoff Volume =							
Inflow Hydrograph Volume =	0.856	2.271	2.925	3.563	5.073	5.852	acre-ft
Time to Drain 97% of Inflow Volume =	>144	>144	>144	>144	>144	>144	hours
Time to Drain 99% of Inflow Volume =	>144	>144	>144	>144	>144	>144	hours
Maximum Ponding Depth =	4.79	6.59	7.20	7.64	8.46	8.63	ft
Maximum Poned Area =	0.58	0.93	0.98	1.03	1.15	1.21	acres
Maximum Volume Stored =	0.848	2.234	2.819	3.258	4.135	4.332	acre-ft

Stormwater Detention and Infiltration Design Data Sheet

