



Prevent • Promote • Protect

Environmental Health Division
1675 W. Garden of the Gods Road
Suite 2044
Colorado Springs, CO 80907
(719) 578-3199 *phone*
(719) 578-3188 *fax*
www.elpasocountyhealth.org

Bradley Point, Filing No.1, MS-21-2

Please accept the following comments from El Paso County Public Health regarding the project referenced above:

- The two lots combined will be dry lots. No water is proposed for the project.
- A finding for sufficiency in terms of water quality is not required.
- The water quality detention basin must be constructed to prevent stagnant water and breeding areas for mosquitos and the risk of West Nile Virus.
- Contact El Paso County Public Health for a Construction Activity Permit due to earth moving exceeding 1-acre, but less than 25-acres.

Mike McCarthy
El Paso County Public Health
719-332-5771
mikemccarthy@elpasoco.com
16February2024