

# ENG-SF21021-R1-TIS.pdf Markup Summary

---

1 (1)

---

Public Works Engineering  
Traffic Technical Memorandum  
(LSC #5214200)  
March 26, 2021  
PCD File No. SF-21-021

It is noted that the information was prepared under my responsibility and to the best of my knowledge and belief, it is true and correct. So far as is consistent with the standard of care.

**Subject:** Text Box  
**Page Index:** 1  
**Date:** 7/1/2021 12:10:26 PM  
**Author:** dsdrice  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** 1

PCD File No. SF-21-021

---

7 (1)

---



**Subject:** Callout  
**Page Index:** 7  
**Date:** 7/2/2021 2:29:17 PM  
**Author:** dsdrice  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** 7

Item V6 on Table 3 of Homestead North TIS: "Improve Vollmer Road between Sam Bass Drive and Poco Road to a 4-lane Urban Minor Arterial but with necessary lane transitions, redirect tapers, etc. south of Poco to adequately transition between the 4-Lane Urban Minor Arterial Cross Section and the 2-Lane Rural Arterial Cross Section north of Poco Road." If this plat is approved and recorded prior to the first Homestead North plat, additional agreement or SIA clause will be required to address construction from Poco to Briargate.

---

16 (1)

---

Provide figure for Background + Filings 1 and 2

**Subject:** Text Box  
**Page Index:** 16  
**Date:** 7/2/2021 2:02:08 PM  
**Author:** dsdrice  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** 16

Provide figure for Background + Filings 1 and 2