



Prevent • Promote • Protect

Environmental Health Division  
1675 W. Garden of the Gods Road  
Suite 2044  
Colorado Springs, CO 80907  
(719) 578-3199 *phone*  
(719) 578-3188 *fax*  
[www.elpasocountyhealth.org](http://www.elpasocountyhealth.org)

**1450 Valley Street, PPR-22-58**

Please accept the following comments from El Paso County Public Health regarding the project referenced above:

- Water service will be provided by Cherokee Metropolitan District. The water system is assigned the PWSID #CO0121125 from the Colorado Department of Public Health and Environment. El Paso County Public Health has made a finding for sufficiency in terms of water quality.
- Wastewater service will be provided by Cherokee Metropolitan District.
- Radon resistant construction building techniques/practices are encouraged to be used in this area. The EPA has determined that Colorado, and the El Paso County area have potentially higher radon levels than other areas of the country.
- Earthmoving activity more than one acre, but less than twenty-five acres, requires a local Construction Activity Permit from El Paso County Public Health. Go to <https://www.elpasocountyhealth.org/service/air-quality/construction-activity-application> for more information.

Mike McCarthy  
El Paso County Public Health  
719.575-8602  
[mikemccarthy@elpasoco.com](mailto:mikemccarthy@elpasoco.com)  
13January2023