



Prevent • Promote • Protect

Environmental Health Division  
1675 W. Garden of the Gods Road  
Suite 2044  
Colorado Springs, CO 80907  
(719) 578-3199 *phone*  
(719) 578-3188 *fax*  
[www.elpasocountyhealth.org](http://www.elpasocountyhealth.org)

### Triple H Ranch, P-25-1

Please accept the following comments from El Paso County Public Health regarding the project referenced above:

- El Paso County Public Health currently has no opposition with the request to rezone from A-35 to 2.5-acre minimum lot sizes. Suitability of the site for the use of onsite wastewater treatment systems (OWTS) appears to be acceptable at this time, but a final determination will be made as the required soil tests are submitted for review.
- All future structures within the 760-acre overall site that generate wastewater must have an approved OWTS Permit for the installation of Onsite Wastewater Treatment Systems per Chapter 8 of the El Paso County Board of Health Regulations.
- A central water system with two drilled wells is planned for the development project. The water system must meet the design criteria of the Colorado Department of Public Health and Environment, Water Quality Control Division, for community water systems.

Mike McCarthy  
El Paso County Public Health  
719-332-5771  
[mikemccarthy@elpasoco.com](mailto:mikemccarthy@elpasoco.com)  
31January2025