

WELL PERMIT NUMBER	37292 -		A	
DIV. 2	CNTY. 21	WD 10	DES. BASIN	MD

APPLICANT

ROBERT CHAPMAN  
6925 WYOMING LANE  
COLO SPRNG CO 80922-

Lot: Block: Filing: Subdiv:

APPROVED WELL LOCATION  
EL PASO COUNTY

NW 1/4 SE 1/4 Section 8  
Twp 13 S RANGE 65 W 6th P.M.

DISTANCES FROM SECTION LINES

2300 Ft. from South Section Line  
1600 Ft. from East Section Line

PERMIT TO USE AN EXISTING WELL

ISSUANCE OF THIS PERMIT DOES NOT CONFER A WATER RIGHT  
CONDITIONS OF APPROVAL

- 1) This well shall be used in such a way as to cause no material injury to existing water rights. The issuance of the permit does not assure the applicant that no injury will occur to another vested water right or preclude another owner of a vested water right from seeking relief in a civil court action.
- 2) The construction of this well shall be in compliance with the Water Well Construction Rules 2 CCR 402-2, unless approval of a variance has been granted by the State Board of Examiners of Water Well Construction and Pump Installation Contractors in accordance with Rule 18.
- 3) Approved pursuant to CRS 37-92-602(3)(c) for the relocation of an existing well, permit 37292. The old well must be plugged and sealed according to the Water Well Construction Rules within ninety (90) days of completion of the new well. **The enclosed Well Abandonment Report form must be completed and submitted to affirm that the old well was properly plugged and sealed.**
- 4) The use of ground water from this well is limited to ordinary household purposes inside one single family dwelling, the watering of domestic animals, and the irrigation of not more than 43,560 square feet of home gardens and lawns.
- 5) Plain casing must be installed and properly grouted to a minimum depth of 40 feet to prevent diversion of water above this depth. The depth of the well shall not exceed 775 feet, which corresponds to the base of the Denver aquifer.
- 6) The maximum pumping rate shall not exceed 15 GPM.
- 7) This well shall be not more than 200 feet from the location sp
- 8) Approved for the use of an existing well constructed on 9/16/98 to a depth of 280 feet, under emergency verbal approval 98-VE-408, granted 9/9/98.

CONTACT COLORADO DIVISION OF WATER RESOURCES.  
(303) 866-3581  
<https://dwr.colorado.gov/>  
Your current well permit is for 1 single-family dwelling only. This request is for a commercial business in addition to the existing residence.


NOTE: To insure a maximum productive life of this well, perforated casing should be set through the entire producing interval of the approved zone or aquifer indicated above.

NOTE: The ability of this well to withdraw its authorized amount of water from this non-renewable aquifer may be less than the 100 years upon which the amount of water in the aquifer is allocated, due to anticipated water level declines.

NOTE: Verbal approval 98-VE-385 was cancelled upon issuance of Verbal approval 98-VE-408.

APPROVED  
DAN

  
State Engineer



Receipt No. 0437811

DATE ISSUED

DEC 04 1998

By

EXPIRATION DATE

DEC 04 2000