

Max amount of foot candles should be 10 unless at a loading and unloading platform, where it can be a maximum of 20 foot candles.

All lighting fixtures need to be shielded or concealed

All lights should be shown in a lighting detail.

6.2.3.B.1 is the section where you can find the lighting standards.

Luminaire Schedule						
Symbol	Qty	Label	Arrangement	Total Lamp Lumens	LLF	Description
	30	F-ALX	SINGLE	N.A.	0.420	ALX3
	16	F-ALX-B	SINGLE	N.A.	0.220	ALX3

Calculation Summary						
Label	CalcType	Units	Avg	Max	Min	Avg/Min
SITE	Illuminance	Fc	0.56	21.8	0.0	N.A.


DETAIL PHOTOMETRIC SITE PLAN
 SCALE: 1:10
 NORTH

**SHORT STOP RESTAURANT
 DEVELOPMENT PLAN MINOR AMENDMENT**
 5819 PALMER PARK BLVD.
 COLORADO SPRINGS, CO. 80915

PROJECT NO.
 DRN BY:
 RMB
 REVISIONS:

Markup Summary

dsdkendall (1)



Subject: Text Box
Page Label: [1] Photometric plan - Short Stop-DP-4
Lock: Unlocked
Author: dsdkendall
Date: 12/17/2018 10:36:25 AM
Color: ■

Max amount of foot candles should be 10 unless at a loading and unloading platform, where it can be a maximum of 20 foot candles..

All lighting fixtures need to be shielded or concealed

All lights should be shown in a lighting detail.

6.2.3.B.1 is the section where you can find the lighting standards.