



Prevent • Promote • Protect

Environmental Health Division
1675 W. Garden of the Gods Road
Suite 2044
Colorado Springs, CO 80907
(719) 578-3199 *phone*
(719) 578-3188 *fax*
www.elpasocountyhealth.org

Rolling Thunder Business Park, Peak Gymnastics, PPR-18-035

Please accept the following comments from El Paso County Public Health regarding the project referenced above:

- Water and wastewater services will be provided by a CDPHE approved district.
- Radon resistant construction building techniques/practices are encouraged to be used in this area. The EPA has determined that Colorado, and the El Paso County area have potentially higher radon levels than other areas of the country.
- El Paso County Public Health requires interior finish plans to be submitted for review and approval prior to commencement of construction.
- Earthmoving activity in excess of one acre, but less than twenty-five acres, requires a local Construction Activity Permit from El Paso County Public Health. Go to <https://www.elpasocountyhealth.org/service/air-quality/construction-activity-application> for more information.

Mike McCarthy, R.E.H.S.
El Paso County Public Health
Environmental Health Division
719.575-8602
mikemccarthy@elpasoco.com
14August2018