



Prevent • Promote • Protect

Environmental Health Division  
1675 W. Garden of the Gods Road  
Suite 2044  
Colorado Springs, CO 80907  
(719) 578-3199 *phone*  
(719) 578-3188 *fax*  
[www.elpasocountyhealth.org](http://www.elpasocountyhealth.org)

**Mountain Splendor Services, Inc., PPR-18-017**

Please accept the following comments from El Paso County Public Health for the project referenced above:

- The permitted and approved onsite wastewater treatment system (OWTS) was installed in 1988 and sized for a 3 bedroom house. The soil treatment area (STA) is located south and east of the house/office, and is not identified on the site plan. A map of the OWTS components is available on the El Paso County Assessor's Office website: <http://www.land.elpasoco.com/default.aspx>
- The existing primary STA must be located, and traffic control measures must be taken to protect it from compaction by vehicular traffic. There must be an equally sized secondary STA site identified and protected from compaction that meets the 100' setback from the existing well. This site is required in the event that the primary site were to require repair or replacement.

Mike McCarthy, R.E.H.S.  
El Paso County Public Health  
Environmental Health Division  
719.575.8602  
[mikemccarthy@elpasoco.com](mailto:mikemccarthy@elpasoco.com)  
30Apr2018