

RE: Meineke Colorado Springs > Inbox x



Matt Klimek

to me, Antony, Desi ▾

Thu, May 16, 6:22 AM (4 days ago)

Delora,

If you have Gabe's email address, I can send this to him or you can. Attached are the spec's for the particular LEDs we are using in the cabinet.

The footcandles at the ROW will be 0.1 or lower. The cabinet being 10' from the P/L and 20' in the air will assure this. Let me know if this is sufficient or if you need anything more asap.

Regards,

Matt

Matthew Klimek / Signs Unlimited



Office: 919-552-8689 / Fax: 919-5571322
6801 Mount Hermon Church Rd, Suite C, Durham, NC 27705
<http://www.signsunlimitedusa.com>

