

# ENG-CDR20005-V1-CD-Marksheffel-Redlines Summary\_Markup Summary

1 (2)



**Subject:** EPC ENG Review  
**Page Index:** 1  
**Date:** 7/28/2020 1:03:44 PM  
**Author:** dsdrice  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** SI01

See comment letter also.  
See City comments.

**Subject:** Text Box  
**Page Index:** 1  
**Date:** 7/28/2020 1:05:32 PM  
**Author:** dsdrice  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** SI01

See comment letter also.


See City comments.

2 (4)




**Subject:** Text Box  
**Page Index:** 2  
**Date:** 7/28/2020 1:06:18 PM  
**Author:** dsdrice  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** SI02

Verify compliance with new Chapter 6 and std details.




**Subject:** Callout  
**Page Index:** 2  
**Date:** 7/28/2020 1:07:02 PM  
**Author:** dsdrice  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** SI02

Is the City going to accept this?



**Subject:** Callout  
**Page Index:** 2  
**Date:** 7/28/2020 1:17:26 PM  
**Author:** dsdrice  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** SI02


and the City of COS



**Subject:** Cloud+  
**Page Index:** 2  
**Date:** 7/28/2020 1:17:54 PM  
**Author:** dsdrice  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** SI02

DPW

3 (2)



**Subject:** Callout  
**Page Index:** 3  
**Date:** 7/28/2020 1:23:13 PM  
**Author:** dsdrice  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** SI03


This needs to be built with the roads if the roads are preceding Filing 2



**Subject:** Callout  
**Page Index:** 3  
**Date:** 7/28/2020 1:27:49 PM  
**Author:** dsdrice  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** SI03

recommend setting this segment below 2% to avoid ADA issue


5 (1)



**Subject:** Callout  
**Page Index:** 5  
**Date:** 7/28/2020 1:36:14 PM  
**Author:** dsdrice  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** SI05

This needs to be included with these plans unless these plans are attached to the subdivision approval. The GEC Plan shows full grading and pipe installation; please clarify.

6 (1)



**Subject:** Callout  
**Page Index:** 6  
**Date:** 7/28/2020 1:34:48 PM  
**Author:** dsdrice  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** SI06

left arrow?