

# ENG-CDR20005-R2-GEC-Redlines.pdf Markup Summary

1 (1)


**Y 2021**

005 / SF-20-015

**Subject:** Text Box  
**Page Index:** 1  
**Date:** 2/27/2021 3:34:04 PM  
**Author:** dsdrice  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [1] 1 CV01

/ SF-20-015

2 (2)



**Subject:** Engineer  
**Page Index:** 2  
**Date:** 2/25/2021 2:38:54 PM  
**Author:** CFurchak  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [2] 2 GR01 - GR01

Sediment Basins should be Initial/Interim.

Show Sediment basin locations and provide details for each temporary sediment basin, including riser pipe perforation sizing, number of rows, required volume, and tributary area to the sediment basin. Unresolved.



**Subject:** Engineer  
**Page Index:** 2  
**Date:** 2/25/2021 4:18:30 PM  
**Author:** CFurchak  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [2] 2 GR01 - GR01

Call out areas of work covered under SF-20-015, not to be completed under CDR-20-005


3 (1)




**Subject:** Callout  
**Page Index:** 3  
**Date:** 2/27/2021 3:41:21 PM  
**Author:** dsdrice  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [3] 3 GR01 - GR02

Consider placing inlet at ultimate location

6 (3)




**Subject:**  
**Page Index:** 6  
**Date:** 2/25/2021 12:39:40 PM  
**Author:** dsdrice  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [6] 6 GR01 - GR05



**Subject:** Callout  
**Page Index:** 6  
**Date:** 2/27/2021 3:49:00 PM  
**Author:** dsdrice  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [6] 6 GR01 - GR05


Is a culvert required for the access road?



**Subject:** Callout  
**Page Index:** 6  
**Date:** 2/27/2021 3:54:57 PM  
**Author:** dsdrice  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [6] 6 GR01 - GR05


Verify that additional protection isn't required through the bottom of the channel. Please provide a detail of this area.

7 (3)




**Subject:** Callout  
**Page Index:** 7  
**Date:** 2/27/2021 3:59:26 PM  
**Author:** dsdrice  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [7] 7 GR01-Marksheffel - GR01

Grading along Marksheffel needs to have a bench for the 25-foot County trail easement. Verify City requirements on the SW side.



**Subject:** Callout  
**Page Index:** 7  
**Date:** 2/27/2021 4:00:57 PM  
**Author:** dsdrice  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [7] 7 GR01-Marksheffel - GR01


Grading along Vollmer needs to show bench and meet ADA sidewalk requirements. See cross-section redlines.



**Subject:** Text Box  
**Page Index:** 7  
**Date:** 2/27/2021 4:08:12 PM  
**Author:** dsdrice  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [7] 7 GR01-Marksheffel - GR01


Show the existing emergency access road that needs to remain unobstructed or otherwise relocated during construction.

9 (8)




**Subject:** Callout  
**Page Index:** 9  
**Date:** 2/27/2021 4:09:34 PM  
**Author:** dsdrice  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [9] 9 GR01-Vollmer - GR01 Vollmer

on ROW line




**Subject:** Callout  
**Page Index:** 9  
**Date:** 2/27/2021 4:13:02 PM  
**Author:** dsdrice  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [9] 9 GR01-Vollmer - GR01 Vollmer

Provide a separate exhibit showing Marksheffel improvements and grading concept on this side of Vollmer (with the same extents as this plan). If the City does not commit to annexing this segment, transition across the intersection to County cross-section.




**Subject:** Callout  
**Page Index:** 9  
**Date:** 2/27/2021 4:15:16 PM  
**Author:** dsdrice  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [9] 9 GR01-Vollmer - GR01 Vollmer

Include removal of old road in limits of construction. (See redlines on cross-sections.)




**Subject:** Callout  
**Page Index:** 9  
**Date:** 2/27/2021 4:16:39 PM  
**Author:** dsdrice  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [9] 9 GR01-Vollmer - GR01 Vollmer

Include sidewalk in limits of construction. verify use of City easement or new easement at this end.




**Subject:** Callout  
**Page Index:** 9  
**Date:** 2/27/2021 4:18:05 PM  
**Author:** dsdrice  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [9] 9 GR01-Vollmer - GR01 Vollmer

show and label existing improvements and utilities




**Subject:** Callout  
**Page Index:** 9  
**Date:** 2/27/2021 4:18:57 PM  
**Author:** dsdrice  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [9] 9 GR01-Vollmer - GR01 Vollmer

Location of this VTC doesn't make sense.



**Subject:** Callout  
**Page Index:** 9  
**Date:** 2/27/2021 4:21:08 PM  
**Author:** dsdrice  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [9] 9 GR01-Vollmer - GR01 Vollmer

Provide bench per std. detail SD\_2-5. Show all necessary grading/construction and permanent slope easements.



---

**Subject:** Callout  
**Page Index:** 9  
**Date:** 2/27/2021 4:23:31 PM  
**Author:** dsdrice  
**Color:** ■  
**Layer:**  
**Space:**  
**Page Label:** [9] 9 GR01-Vollmer - GR01 Vollmer

Label existing and proposed ROW or include in legend. NEPEs will be required for construction prior to platting.