

# cd-review1.pdf Markup Summary

1 (1)

003

**Subject:** Text Box  
**Page Label:** 1  
**Author:** CDurham  
**Date:** 2/23/2023 6:14:15 PM  
**Status:**  
**Color:** ■  
**Layer:**  
**Space:**


003



**Subject:** Re: Text Box  
**Page Label:** 1  
**Author:** Rich  
**Date:** 3/16/2023 10:30:43 AM  
**Status:**  
**Color:** ■  
**Layer:**  
**Space:**

added

3 (4)



**Subject:** Callout  
**Page Label:** 3  
**Author:** CDurham  
**Date:** 2/27/2023 9:02:57 AM  
**Status:**  
**Color:** ■  
**Layer:**  
**Space:**

Plat shows min distance as 25' min. Please coordinate between this sheet and plat so details have the same information.



**Subject:** Re: Callout  
**Page Label:** 3  
**Author:** Rich  
**Date:** 3/16/2023 12:00:21 PM  
**Status:**  
**Color:** ■  
**Layer:**  
**Space:**

plat updated

Type A or (RAMI

**Subject:** Text Box  
**Page Label:** 3  
**Author:** CDurham  
**Date:** 2/27/2023 9:03:19 AM  
**Status:**  
**Color:** ■  
**Layer:**  
**Space:**

Type A or



**Subject:** Re: Text Box  
**Page Label:** 3  
**Author:** Rich  
**Date:** 3/16/2023 11:41:44 AM  
**Status:**  
**Color:** ■  
**Layer:**  
**Space:**

added

SID  
Type A or  
OPTIONA

---

**Subject:** Text Box  
**Page Label:** 3  
**Author:** CDurham  
**Date:** 2/27/2023 9:03:27 AM  
**Status:**  
**Color:** ■  
**Layer:**  
**Space:**

Type A or



---

**Subject:** Re: Text Box  
**Page Label:** 3  
**Author:** Rich  
**Date:** 3/16/2023 11:41:51 AM  
**Status:**  
**Color:** ■  
**Layer:**  
**Space:**

added



---

**Subject:** Callout  
**Page Label:** 3  
**Author:** CDurham  
**Date:** 2/27/2023 9:04:22 AM  
**Status:**  
**Color:** ■  
**Layer:**  
**Space:**

Per typical section on GEC plan set, public improvement easement is 10'. Update sections between plan sets to be consistent.



---

**Subject:** Re: Callout  
**Page Label:** 3  
**Author:** Rich  
**Date:** 3/16/2023 11:43:58 AM  
**Status:**  
**Color:** ■  
**Layer:**  
**Space:**

change grading plan to 5'