



ENG-SF21032-R2-CDs.pdf Markup Summary

1 (2)




Subject: Callout
Page Index: 1
Date: 3/22/2022 3:18:55 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: [1] 1 CV01- Street Plans - CV01

Type A or Modified Type C



Subject:
Page Index: 1
Date: 3/22/2022 3:19:03 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: [1] 1 CV01- Street Plans - CV01


4 (1)



Subject: Callout
Page Index: 4
Date: 3/22/2022 3:25:01 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: [4] 4 DINES BLVD


Do you want the point numbers that are on this sheet?

8 (5)




Subject: Callout
Page Index: 8
Date: 3/23/2022 4:17:29 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: [9] 9 PENNYDALE DR


Please label cross-slopes




Subject: Arrow
Page Index: 8
Date: 3/23/2022 4:17:37 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: [9] 9 PENNYDALE DR



Subject: Arrow
Page Index: 8
Date: 3/23/2022 4:18:16 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: [9] 9 PENNYDALE DR




Subject: Arrow
Page Index: 8
Date: 3/23/2022 4:17:44 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: [9] 9 PENNYDALE DR



Subject: Callout
Page Index: 8
Date: 3/23/2022 4:19:17 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: [9] 9 PENNYDALE DR

If the profile can be raised to aid in gutter drainage that is recommended.


11 (1)



Subject: Callout
Page Index: 11
Date: 3/22/2022 4:07:27 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: [13] 13 2518802DT01 - 2518800DT01

Please rotate the view to match the profiles.


12 (1)



Subject: Callout
Page Index: 12
Date: 3/22/2022 5:12:04 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: [13] 13 2518802DT01 - 2518800DT01

Lettering and abbreviations need to be per S&S std. note #7


16 (1)




Subject: Callout
Page Index: 16
Date: 3/23/2022 8:11:19 AM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: [13] 13 2518802DT01 - 2518800DT01

Should be 6' with 36" pipe? Verify.


29 (7)




Subject:
Page Index: 29
Date: 3/22/2022 5:22:30 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: [13] 13 2518802DT01 - 2518800DT01



Subject:
Page Index: 29
Date: 3/22/2022 5:22:54 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: [13] 13 2518802DT01 - 2518800DT01




Subject:
Page Index: 29
Date: 3/22/2022 5:23:23 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: [13] 13 2518802DT01 - 2518800DT01




Subject: Callout
Page Index: 29
Date: 3/22/2022 5:23:56 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: [13] 13 2518802DT01 - 2518800DT01

Show storm




Subject: Callout
Page Index: 29
Date: 3/22/2022 5:24:06 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: [13] 13 2518802DT01 - 2518800DT01

Show water, san



Subject: Callout
Page Index: 29
Date: 3/22/2022 5:24:38 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: [13] 13 2518802DT01 - 2518800DT01

Show water



Subject: Callout
Page Index: 29
Date: 3/22/2022 5:48:11 PM
Author: dsdrice
Color: ■
Layer:
Space:
Page Label: [13] 13 2518802DT01 - 2518800DT01

Add note that pothole locates are required prior to construction and any other CSU requirements.