


Key
Wall Light

NOTE: The full building plan sets, to include MEP, are not yet completed. The applicant is waiting until after the initial review of the so that it can be determined there are no changes that need to be made to the building layout. All lights are wall-mounted lights are integrated into the building. The photometric plan will be submitted with review 2.

Please submit this document for the second review in a format that is not sideways and difficult to review

Note: staff will not review this document until the second review when a full photometric plan is submitted.



APPLICANT/SCALE DRAWERS
 VERTX CONSULTING SERVICES
 444 E. 10th Ave
 Colorado Springs, Colorado 80905
 719-573-8605
 info@vertexcs.com

PCD FILE NO. PPRXXXX



<p>444 E. 10th Ave Colorado Springs, Colorado 80905 719-573-8605</p>		<p>THE ONEIL GROUP CO. 4WAY COMMERCIAL LIGHTING PLAN</p>	<table border="1"> <thead> <tr> <th>NO.</th> <th>REVISION/ISSUE</th> <th>DATE</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td></tr> </tbody> </table>	NO.	REVISION/ISSUE	DATE																			<p>FOR REVIEW</p>	<p>GENERAL NOTES</p>
NO.	REVISION/ISSUE	DATE																								
<p>PROJECT NO. 1116/23</p> <p>DATE 11/16/23</p> <p>DESIGNED BY GJM</p> <p>APPROVED CJD</p>	<p>SHEET P1</p>																									

LARGE SLIM PROFILE WALL PACK

OUTDOOR

FEATURES

- Bronze die-cast aluminum housing with hinged front frame
- Custom and factory select colors available (Contact factory for pricing)
- 1/2" coin plug with o-rings for condensation protocol
- Tempered glass lens
- Type III (WPL-P-50W), Type II (WPL-P-80W)
- 100% dimmable (0-10V) or on junction box mounting (dd)
- 4000K and 5000K CCT
- 120-277V Universal Voltage
- 5 Year Warranty
- ETL Listed for Wet Location
- DesignLights Consortium® Qualified Luminaire



SUITABLE APPLICATIONS

- Parking Lots
- Buildings
- General Area Lighting
- Wet Wash
- Walkways





407-478-3759
www.infil-llc.com

LED SYSTEMS INFORMATION	50W		80W	
	>100K	>100K	>100K	>100K
Calculated L ₇₀ (TM-21)	4000K	4000K	5000K	5000K
Delivered Lumens	3,076 lm	3,142 lm	4,395 lm	7,566 lm
Total Input Watts	51 W	77 W	53 W	78 W
Luminaire Efficacy Rating (LER)	98 lm/W	106 lm/W	94 lm/W	102 lm/W
Correlated Color Temperature (CCT)	4000K	4000K	5000K	5000K
Color Rendering Index (CRI)	>80	>80	>70	>70
Maximum Ambient Temperature	105 F	115 F	105 F	115 F
Universal Driver	120-277 V	120-277 V	120-277 V	120-277 V

LED System data shown based on WPL-P-50W/LED-UNIV-400K, WPL-P-80W/LED-UNIV-400K, WPL-P-50W/LED-UNIV-5000K & WPL-P-80W/LED-UNIV-5000K
LED System Performance Curves based on IESNA projections for high pressure Na 20 C equivalent.

PHOTOMETRIC REPORTS



GENERAL NOTES

FOR REVIEW	
NO.	REVISION/ISSUE

THE ONEIL GROUP CO.
4-WAY COMMERCIAL
LIGHTING PLAN



PROJECT NO.	DATE	REVISION	DATE
	11/16/23		

DATE: 11/16/23
PROJECT: 4-WAY COMMERCIAL LIGHTING PLAN
DRAWN: CAG
CHECKED: CAG

P2

484 E. 1st Avenue
Colorado Springs, CO 80903
719-333-8005
info@vertexcs.com

0' 50' 100'

PCD FILE NO. PPRXXXX

