



Prevent • Promote • Protect

Environmental Health Division
1675 W. Garden of the Gods Road
Suite 2044
Colorado Springs, CO 80907
(719) 578-3199 *phone*
(719) 578-3188 *fax*
www.elpasocountyhealth.org

Rolling Ridge Estates, P-18-001

Please accept the following comments from El Paso County Public Health regarding the rezoning request referenced above:

- **El Paso County Public Health (EPCPH) has no known issues with the requested zone changes from the current RR-5 zoning provided all applicable rules and regulations of EPCPH are complied with as the site is developed.**
- **All future structures and any existing structures constructed on the site that generate wastewater must install and/or have an approved permit for an Onsite Wastewater Treatment System (OWTS) per Chapter 8 of the El Paso County Board of Health Regulations. All existing private wells and OWTS's must be on the same property (or future lot) as the structure it serves, and meet all minimum installation setbacks.**

**Mike McCarthy, R.E.H.S.
El Paso County Public Health
Environmental Health Division
719.575.8602
mikemccarthy@elpasoco.com
22Mar2018**