



ORIGINAL PERMIT APPLICANT(S)

JASON LISS

APPROVED WELL LOCATION

Water Division: 1 Water District: 1
 Designated Basin: KIOWA-BIJOU
 Management District: N/A
 County: EL PASO
 Parcel Name: N/A
 Physical Address: N/A

SW 1/4 NE 1/4 Section 16 Township 11.0 S Range 64.0 W Sixth P.M.

UTM COORDINATES (Meters, Zone:13, NAD83)

Easting: 538026.0 Northing: 4327287.6

PERMIT TO CONSTRUCT A NEW WELL

ISSUANCE OF THIS PERMIT DOES NOT CONFER A WATER RIGHT
CONDITIONS OF APPROVAL

- 1) This well shall be used in such a way as to cause no material injury to existing water rights. The issuance of this permit does not ensure that no injury will occur to another vested water right or preclude another owner of a vested water right from seeking relief in a civil court action.
- 2) The construction of this well shall be in compliance with the Water Well Construction Rules 2 CCR 402-2, unless approval of a variance has been granted by the State Board of Examiners of Water Well Construction and Pump Installation Contractors in accordance with Rule 18.
- 3) Approved pursuant to CRS 37-90-105 for a well on a tract of land of 39.07 acres in the W1/2 of the W1/2 of the NE1/4 of Section 16, Township 11 South, Range 64 West of the Sixth P.M., El Paso County, also known as Parcel 1, more particularly described on attached Exhibit A.
- 4) Water from this well may be used for domestic purposes inside 3 single family dwellings and the watering of the owner's own large non-commercial domestic animals.
- 5) The irrigated area shall not exceed 1 acre of lawn and garden.
- 6) The pumping rate of this well shall not exceed 15 GPM.
- 7) The annual withdrawal of ground water from this well shall not exceed 3 acre-feet.
- 8) The total depth of the well shall not exceed 825 feet, which corresponds to the base of the Dawson aquifer. At a minimum, plain casing shall be installed and grouted through all unconsolidated materials and shall extend a minimum of ten feet into the bedrock formation to prevent production from other zones.
- 9) This well shall be constructed within 300 feet of the location specified on this permit.

NOTE: The ability of this well to withdraw its authorized amount of water from this non-renewable aquifer may be less than the 100 years upon which the amount of water in the aquifer is allocated, due to anticipated water level declines.

NOTE: This permit will expire on the expiration date unless the well is constructed by that date. A Well Construction and Yield Estimate Report (GWS-31) must be submitted to the Division of Water Resources to verify the well has been constructed. An extension of the expiration date may be available. Contact the DWR for additional information or refer to the extension request form (GWS-64) available at: <http://www.water.state.co.us>

NOTE: This permit has been issued pursuant to the Findings and Order of Determination of Water Right No. 1765-BD - Amendment No. 1 which cancelled a portion of ground water underlying the subject parcel.

Issued By SHANNON JOHNSON

Date Issued: 11/22/2017

Expiration Date: 11/22/2019