



Prevent • Promote • Protect

Environmental Health Division
1675 W. Garden of the Gods Road
Suite 2044
Colorado Springs, CO 80907
(719) 578-3199 *phone*
(719) 578-3188 *fax*
www.elpasocountyhealth.org

9625 Otero Accessory Living Quarters, AL-21-1

Please accept the following comments from El Paso County Public Health (EPCPH) for the special use project referenced above:

- Water service for the existing house is by an individual private well.
- Wastewater service for the existing house is an onsite wastewater treatment system (OWTS) permitted, installed and approved for a 6-bedroom house. The proposed new accessory living quarters will be connected to the existing 2,250-gallon septic tank and the existing 844 sq.ft. soil treatment area, both of which are adequate in size for the new living quarters.
 - An OWTS Minor Repair Permit is required for the connection of the new living quarters to the existing septic tank.
- The existing water line must meet the setback to the new wastewater line or the wastewater line must be properly encased as specified in the OWTS Regulations.

Mike McCarthy R.E.H.S.
El Paso County Public Health
719.575.8602
mikemccarthy@elpasoco.com
24Mar2021