



Prevent • Promote • Protect

Environmental Health Division  
1675 W. Garden of the Gods Road  
Suite 2044  
Colorado Springs, CO 80907  
(719) 578-3199 *phone*  
(719) 578-3188 *fax*  
[www.elpasocountyhealth.org](http://www.elpasocountyhealth.org)

**Direen Extended Family, AL-18-005**

Please accept the following comments from El Paso County Public Health regarding the expired variance of use referenced above:

- **Water service for the existing home and the proposed 1-bedroom mobile home is by an individual well.**
- **Wastewater service for the project is provided by an existing onsite wastewater treatment system (OWTS) that was installed in 1991 and sized and approved for a 3 bedroom house. There is no information on file at El Paso County Public Health regarding the connection of the 1-bedroom mobile home to the existing OWTS. El Paso County Public Health requests any information regarding wastewater treatment associated with the 1-bedroom mobile home be submitted for review.**
- **An OWTS Minor Repair Permit may be required if the installation of the building sewer line connection from the 1 -bedroom mobile home is connected to the existing septic tank.**

**Mike McCarthy, R.E.H.S.  
El Paso County Public Health  
Environmental Health Division  
719.575.8602  
[mikemccarthy@elpasoco.com](mailto:mikemccarthy@elpasoco.com)  
09Mar2018**