


site development plan.pdf Markup Summary

dsdlaforce (3)




Subject: Callout
Page Label: [1] 1 COVER SHEET
Lock: Unlocked
Status:
Checkmark: Unchecked
Author: dsdlaforce
Date: 4/23/2018 6:18:53 PM
Color: ■
Layer:
Space:

Add "PCD File No. PPR-18-012"



Subject: Callout
Page Label: [2] 2 SITE PLAN
Lock: Unlocked
Status:
Checkmark: Unchecked
Author: dsdlaforce
Date: 4/23/2018 6:17:19 PM
Color: ■
Layer:
Space:


update callout to 11



Subject: Callout
Page Label: [3] 3 SITE DETAILS
Lock: Unlocked
Status:
Checkmark: Unchecked
Author: dsdlaforce
Date: 4/23/2018 6:23:03 PM
Color: ■
Layer:
Space:


Revise.
Typical convention is horizontal:vertical

dsdkendall (4)



Subject: Callout
Page Label: [2] 2 SITE PLAN
Lock: Locked
Status:
Checkmark: Unchecked
Author: dsdkendall
Date: 4/26/2018 3:31:46 PM
Color: ■
Layer:
Space:

Show dimensions of the structure




Subject: Callout
Page Label: [2] 2 SITE PLAN
Lock: Locked
Status:
Checkmark: Unchecked
Author: dsdkendall
Date: 4/24/2018 9:12:14 AM
Color: ■
Layer:
Space:

what is this?



Subject: Callout
Page Label: [2] 2 SITE PLAN
Lock: Locked
Status:
Checkmark: Unchecked
Author: dsdkendall
Date: 4/24/2018 9:12:18 AM
Color: ■
Layer:
Space:

Show width of drive thru, must be 8'.



Subject: Callout
Page Label: [4] 4 PHOTOMETRIC PLAN
Lock: Locked
Status:
Checkmark: Unchecked
Author: dsdkendall
Date: 4/26/2018 3:31:50 PM
Color: ■
Layer:
Space:

Poles can be no taller than 15 feet unless they are parking lot fixtures, then 20 feet is allowed.