



Prevent • Promote • Protect

Environmental Health Division
1675 W. Garden of the Gods Road
Suite 2044
Colorado Springs, CO 80907
(719) 578-3199 *phone*
(719) 578-3188 *fax*
www.elpasocountyhealth.org

836 North Gate, Large Day Care Center, AL-25-12

Please accept the following comments from El Paso County Public Health (EPCPH) for the proposed large day care special use.

- Water for the site is provided by an individual well, and with this request may be classified as a Transient, Non-Community Ground Water System by the Colorado Department of Public Health and Environment (CDPHE). Contact CDPHE with an accurate count of the population served per day and information on days per year with greater than 25 people served. Contact the Water Quality Control Division for information at cdphe.commentswqcd@state.co.us 303-692-3500
- An OWTS design engineer must complete an OWTS Verification Change Request to EPCPH to determine if the existing OWTS is sized for the proposed increase in wastewater flow. Call 719-578-3199, option 3, for instructions on how to submit the Verification form.

Mike McCarthy
El Paso County Public Health
719-332-5771
mikemccarthy@elpasoco.com
11July2025