



Prevent • Promote • Protect

Environmental Health Division
1675 W. Garden of the Gods Road
Suite 2044
Colorado Springs, CO 80907
(719) 578-3199 *phone*
(719) 578-3188 *fax*
www.elpasocountyhealth.org

Rocky Top Rezone, I-18-001, (Revised)

Please accept the following comments from El Paso County Public Health for the rezone request referenced above:

- There are no known public health issues associated with the approval of this rezone request.
- The future proposed plans for the office building, employee building, shop, and future shop/storage structures not directly related to the rezone request will require detailed water and wastewater plans to be submitted for review. Proximity to central wastewater must be explored, and is required prior to issuing a permit for the installation of an onsite wastewater treatment system (OWTS).
- Portable chemical toilets are only approved for temporary use. Work staff must have access to a restroom connected to an approved wastewater treatment system.
- A determination of the status of the water system as public or private is based upon the definition in the Colorado Primary Drinking Water Regulations. The Colorado Department of Public Health and Environment, Water Quality Control Division, must be contacted for input on that determination. Contact <https://www.colorado.gov/cdphe/wq-regulations-policies-guidance>

Mike McCarthy, R.E.H.S.
El Paso County Public Health
Environmental Health Division
719.575.8602
mikemccarthy@elpasoco.com
02June2018