



Prevent • Promote • Protect

Environmental Health Division
1675 W. Garden of the Gods Road
Suite 2044
Colorado Springs, CO 80907
(719) 578-3199 *phone*
(719) 578-3188 *fax*
www.elpasocountyhealth.org

Rockwood Lot Line Adjustment, VR-17-010

Please accept the following comments from El Paso County Public Health regarding the project referenced above:

- **Water service for the proposed lots affect by the line adjustment will be provided by Forest View Acres Water District.**
- **Wastewater service for the 2 lots will be onsite wastewater treatment systems.**
- **El Paso County Public Health has no objection to the proposed line adjustment. All regulations for the installation of onsite wastewater treatment systems (OWTS) must be followed. There appears to be sufficient area on both lots for both primary and secondary soil treatment areas. The OWTS installation shall comply with the regulations in effect at the time of application.**

**Mike McCarthy, R.E.H.S.
El Paso County Public Health
Environmental Health Division
719.575.8602
mikemccarthy@elpasoco.com
16Oct2017**