



DONALD WESCOTT FIRE PROTECTION DISTRICT

15415 Gleneagle Drive Colorado Springs, CO 80918

Ph: 719-488-8680 Fx: 719-488-3414

To: Whom it may concern
From: Chief Vinny Burns
Donald Wescott Fire Protection District
Date: August 20, 2019
Re: Sanctuary of Peace P.U.D.

This is a letter of commitment for fire protection by Donald Wescott Fire Protection District for the property located at 15760 Hwy. 83, for the development known as The Sanctuary of Peace Residential Community.

The Donald Wescott Fire Protection District is an ISO protection class 3 department that has two full time staffed fire stations, the closest of which is located at 15505 Hwy. 83.

The district understands that the applicant has proposed modifications to PUD criteria and waivers to the El Paso County Land Development Code. The applicant has proposed 20 ft wide private paved roadways in a 24 ft wide roadway tract. The applicant proposes more than 25 lots on a dead-end road and a dead-end road in excess of 1,600 feet. The applicant also proposes an unpaved 12 ft. wide to 16 ft. wide emergency-only access road from Benet Lane to Fools Gold Lane in an emergency access easement. The emergency access road will be gated and secured in a manner acceptable to the district. The district finds the proposed modifications and waivers to be acceptable.

The Sanctuary of Peace development will be required to provide an on-site 15,000 gallon fire cistern along with a fire turnout to allow the usage of the cistern while not impeding traffic on the roadway. Residential construction will be reviewed by the district and shall comply with district requirements.

If you have any questions or need further information, please feel free to contact me.

Thank you,

Vincent P. Burns
Fire Chief