



Prevent • Promote • Protect

Environmental Health Division  
1675 W. Garden of the Gods Road  
Suite 2044  
Colorado Springs, CO 80907  
(719) 578-3199 *phone*  
(719) 578-3188 *fax*  
[www.elpasocountyhealth.org](http://www.elpasocountyhealth.org)

### **Peaceful Valley Adjustment, EXBL-17-001**

**Please accept the following comments from El Paso County Public Health regarding the project referenced above:**

- **Parcel 5523002013 addressed as 10150 Peaceful Valley Road has a permitted and approved on-site wastewater treatment system (OWTS) installed. The soil treatment area was approved in 1972 and a new septic tank was permitted and installed on 21Oct2016.**
- **Based on the documents submitted for this project, and the records at El Paso County Public Health, it is apparent that the existing OWTS will meet all required installation setbacks when the boundaries are adjusted. Please contact El Paso County Public Health if there are any questions regarding the location of any of the OWTS components.**
- **Note: The soil treatment area must be 10' minimum from the new property line.**

**Mike McCarthy, R.E.H.S.  
El Paso County Public Health  
Environmental Health Division  
719.575.8602  
[mikemccarthy@elpasoco.com](mailto:mikemccarthy@elpasoco.com)  
02May2017**