

Kevin Mastin, Interim Executive Director
El Paso County Planning & Community Development
O: 719-520-6300
KevinMastin@elpasoco.com
2880 International Circle, Suite 110
Colorado Springs, CO 80910

Board of County Commissioners
Holly Williams, District 1
Carrie Geitner, District 2
Stan VanderWerf, District 3
Longinos Gonzalez, Jr., District 4
Cami Bremer, District 5

August 23, 2022

County File: OAR2286

Re: Colorado Springs Airport Filing No. 1G - AR FP 22-00527

To: Gabe Sevigny ; Gabe.Sevigny@coloradosprings.gov

Planning Division

Note that El Paso County does not have land use authority over property within the City of Colorado Springs; however, it is recommended that the development follow these regulations for this site to ensure that proper measures are taken to ensure compatibility between the proposed use within the City and the existing neighborhood and surrounding properties in the County.

El Paso County LDC §6.2.2(D)(2) requires a Buffer Between Non-Residential and Residential Districts Separated by a Non-Arterial Road or Public Alley.

- (1) **Where Required.** A buffer is required along the road-side lot, parcel, or tract line of any non-residential use where the use is separated from a residential zoning district by a non-arterial road or public alley.
- (2) **Depth and Planting Standards.** The required buffer shall be a minimum of 15 feet deep. The minimum number of trees in the buffer shall be 1 tree for every 15 feet of the road frontage. A minimum of $\frac{1}{3}$ of the trees shall be evergreen trees.
- (3) **Opaque Fence or Wall Required.** An opaque fence or wall with a minimum height of 6 feet is required along the inside edge of the required buffer when the area immediately adjacent to the 15 foot buffer is used as a service corridor for loading, maneuvering or storage. If the area is used for parking, the required parking lot screening shall be applicable.
- (4) **Minimum Ground Covering Required.** The required buffer area shall require a ground cover at maturity with a minimum of 75% living plant materials. Bark, wood chips, rock, stone, or other natural landscape material shall be used as a non-living ground cover. Areas of a required buffer not covered in approved living ground cover material shall be covered in an approved non-living ground cover.

Reviewed by: Ashlyn Mathy, Planner I
Ashlynmathy2@gmail.com

Engineering Division

Reviewed by:
Staff requests a copy of the traffic report noted in the application packet.

Reviewed by:
Gilbert LaForce, PE
gilbertlaforce@elpasoco.com

County Engineer (Public Works)

Additional comments may be provided by the County Engineer.

Ashlyn Mathy, Planner I
El Paso County Development Services
2880 International Circle, Colorado Springs, CO, 80910
(719) 520-6447

2880 INTERNATIONAL CIRCLE, SUITE 110
PHONE: (719) 520-6300



COLORADO SPRINGS, CO 80910-3127
FAX: (719) 520-6695