






# Markup Summary

dsdsevigny (3)

---




**Subject:** Callout  
**Page Label:** 1  
**Lock:** Locked  
**Status:**  
**Checkmark:** Unchecked  
**Author:** dsdsevigny  
**Date:** 12/12/2017 5:28:05 PM  
**Color:** ■

Alternative Lighting Plan request addressed in LOI, Director approval required, his comments are that the Foot Candles need to be addressed before he can grant approval.



**Subject:** Highlight  
**Page Label:** 1  
**Lock:** Locked  
**Status:**  
**Checkmark:** Unchecked  
**Author:** dsdsevigny  
**Date:** 12/12/2017 5:28:04 PM  
**Color:** ■



**Subject:** Callout  
**Page Label:** 1  
**Lock:** Locked  
**Status:**  
**Checkmark:** Unchecked  
**Author:** dsdsevigny  
**Date:** 12/12/2017 5:28:02 PM  
**Color:** ■

Per 6.2.3 Lighting (e) Light levels measured at the property line of the development site adjacent to residential property or public right of way shall not exceed 0.1 foot candles as a direct result of the on-site lighting.