



Prevent • Promote • Protect

Environmental Health Division
1675 W. Garden of the Gods Road
Suite 2044
Colorado Springs, CO 80907
(719) 578-3199 *phone*
(719) 578-3188 *fax*
www.elpasocountyhealth.org

Mose Rezone, P-20-6

Please accept the following comments from El Paso County Public Health (EPCPH) regarding the 6.21-acre, 2-residential lots (1-3.0-acre, 1-3.21-acre) project referenced above:

- There are no public health issues noted with the proposed rezone noted by El Paso County Public Health.
- Each lot developed must have an approved Onsite Wastewater Treatment Sysyem (OWTS) Permit issued prior to lot development. All minimum horizontal OWTS installation setbacks must be met.

Mike McCarthy
El Paso County Public Health
mikemccarthy@elpasoco.com
719-575-8602
10Jan2021